

American Bureau of Shipping

Certificate Nº: SQ5197995-22

Owner No.: FLNU 600422-0

Field Office: ABS Shanghai

UN Portable Tank/Tank Container Production Certificate

Owner <u>FALCON LEASE PTE LTD.</u>

& address 60 PAYA LEBAR ROAD, #12-05, PAYA LEBAR SQUARE, SINGAPORE, 409051

 Manufacturer
 JINGJIANG ASIAN-PACIFIC LOGISTICS EQUIPMENT CO., LTD.
 Serial No.: 2202670

 & address
 NO. 199 XINGANG AVENUE, JINGJIANG, CHINA, 214500
 Serial No.: 2202670

Manufacturer's Model Nº.: A023E-026-0002

APPLICABLE RULES, REGULATIONS AND STANDARDS

ABS Design Type №: AB/124/22 US DOT Identification Code: IA-8101

ABS Approval Ref. №: <u>T2212896 / T2225906</u>

US DOT Approval: 49 CFR <u>§178.273, §178.274, §178.275</u>

CSC Approval Reference: <u>USA/AB-124/22</u>

Customs Approval Reference: <u>USA/124-AB/22</u>

Customs Approval Reference: <u>USA/124-AB/22</u>

International Union of Railways (UIC): <u>IRS 50592</u>

Sec. 6.8 ADR/RID Approval Number: <u>NL/AB-124/22</u>

Sec. 6.8 ADR/RID Approval Number: <u>NL/AB-124/22</u>

Other(s): <u>TC, ISO 668, 1161, 6346, 1496-3</u>

US DoT SP: <u>N/A</u> and/or TC Equiv.Cert.: <u>N/A</u>

CONTAINER CHARACTERISTICS

Overall Length: 6058 mm Width: 2438 mm Height 2591 mm

Maximum Operating Gross Mass: 36000 kg Tare: 3760 kg Max. Permissible Payload: 32240 kg

Allowable Stacking Load for 1.8 g: <u>213360</u> kg Transverse Racking Test Force: <u>150000</u> newtons

TANK CHARACTERISTICS

ISO Size/Type Code: 22K2

Design Code: ASME BPVC.VIII.1 & EN 14025 Liquid Capacity at 20°C: 25950 liters (total)

Overall Tank Length: 6029 mm Outside Tank Diameter: 2423 mm

Head Matl Spec.: SANS 50028-7:1.4402Head Thickness: 4.6 mm (as built after forming)Head Corrosion Allowance: 0.2 mmShell Matl Spec.: SANS 50028-7:1.4402Shell Thickness: 4.6 mm (as built)Shell Corrosion Allowance: 0.42 mm

Equiv. Reference Steel Thickness: 6 mm

MAWP: 4 bar MAWP of Heating System: 4 bar

External Design Pressure: 0.41 bar

Design Temperature Range: Min.: -40 °C; Max.: 130 °C

Coating/Lining: Type: N/A & Thickness: N/A mm

Insulation: Type: Rockwool & Thickness: 50 mm

Baffles: N/A Quantity: N/A Cladding: Type: GRP & Thickness: 1.8/2.0 mm
Discharge: Bottom Bottom Discharge No. of Closures in Series: 3

PRESSURE RELIEF DEVICES

1st; Quantity: <u>1</u> 2nd; Quantity: <u>---</u> 3rd; Quantity: <u>---</u>

 Manufacturer
 Perolo
 -- --

 Catalog Number
 MX65F44TSP
 -- --

 Set Pressure
 4.4 bar
 -- bar

 Rupture
 N/A bar
 -- bar

 Capacity (each)
 4.032 m³/s
 -- m³/s

Total Capacity: 4.032 m³/s

Issued on: 24-Mar-2022 at Jingjiang, Jiangsu, China by Shen, Songxian (Empl. No. 7121)

SERVICE EQUIPMENT

Perolo 3" Bottom Discharge, 1.5" Air Line, 3" Top Discharge Provision

TESTING INFORMATION

Prototype Test Certificate: SQ5160313-A, dated: 09-Mar-2022 Rail Impact Test Certificate/Report: SQ5038404-A, dated: 21-Jan-2022

TC Impact Approved: Yes

PRESSURE TEST

Test Pressure of Tank: 6 bar, dated: 15-Mar-2022 Test Pressure of Heating System: 6 bar, dated: 14-Mar-2022

Leak Proof Test of Container: 1 bar, dated: 17-Mar-2022

Approved Commodities: Compatibilities commodities as per T11 / L4BN

Portable Tank Instruction: <u>T11</u> ADR/RID Tank Code: <u>L4BN</u>

Stamping tank-plate Next Inspection Date: 09/2024

Additional Information/Comments: The compatibilities between commodities and service equipment/pressure relief devices/vessel/gaskets are the responsibility of the

owner. Shipping name/special provisions markings are the responsibility of the owner.

Request Reviewed and NO Conflict of Interest Identified.

This Certificate evidences compliance with one or more of the Rules, guides, standards, or other critical and the Rules of Shipping and is issued solely for the use of the Bureau, its committees, its clients or other authorized entities. This Certificate is a representation only that he Coulomb the Rules of Shipping and its issued solely for the use of the Rules, guides, standards, or other criteria of American Bureau of Shipping. The validity, applicability and interpretate the rules of Shipping who shall remain the sole judge thereof. Nothing contained in this Certificate or in any Report/squed in contemptation of this Certificate shall be deemed to relieve any designer, builder, owner, manufacturer, seller, supplier, repairer, operator, or other entity of any warranty express scimplied.

CNT-SFM-00058 Revision 3 Page 1 of 1